



FIRE ALARM INSPECTION REPORT INSP# 1036 5-2023

SITE BRENTON RESIDENCE 417 VALERIE CT INCLINE VILLAGE , NV 89451 INSPECTION DATE 5/9/2023	TESTING AGENCY BATTLEBORN ALARM 59 DAMONTE RANCH PKWY SUITE B541 RENO, NV 89521 PHONE # 775-796-1911	CENTRAL MONITORING STATION ALL AMERICAN MONITORING 1301 Sarasota Center Blvd Sarasota, FL 34240 PHONE # (800) 318-9486 LICENSE 142301-002
---	---	--

CONTROL UNIT PASS	PANEL OPERATION	
LAMPS PASS	SUPERVISION PASS	REMOTE POWER PANELS PASS
TEST FUSES PASS	TROUBLE SIGNALS PASS	LOCAL ANNUNCIATORS N/A
GROUND FAULT PASS	DISCONNECT SWITCHES PASS	REMOTE ANNUNCIATORS PASS

CENTRAL STATION SIGNALS

ALARM PASS	RESTORE PASS	SUPERVISORY PASS	RESTORE PASS	TROUBLE PASS	RESTORE PASS
-------------------	---------------------	-------------------------	---------------------	---------------------	---------------------

INITIATING

ZONE	DEVICE TYPE	LOCATION	STATUS
01	WATERFLOW	WATERFLOW LOWER LEVEL MECHANICAL	PASS
02	SMOKE DETECTOR	FACP SMOKE DETECTOR	PASS
03	SMOKE DETECTOR	LOWER LEVEL IN FRONT OF ELEVATOR	PASS
04	SMOKE DETECTOR	1ST FLOOR IN FRONT OF ELEVATOR	PASS
05	SMOKE DETECTOR	2ND FLOOR IN FRONT OF ELEVATOR	PASS
06	SMOKE DETECTOR	TOP OF ELEVATOR SHAFT	PASS
09	SMOKE DETECTOR	LOWER LEVEL BED 2	PASS
09	SMOKE DETECTOR	LOWER LEVEL BED 1	PASS
09	SMOKE DETECTOR	LOWER LEVEL INFRONT OF BEDS 1 AND 2	PASS
09	SMOKE DETECTOR	LOWER LEVEL REC ROOM	PASS
09	SMOKE DETECTOR	BOTTOM OF STAIRS	PASS
10	CO DETECTOR	LOWER LEVEL BED 2	PASS
10	CO DETECTOR	LOWER LEVEL BED 1	PASS
10	CO DETECTOR	LOWER LEVEL INFRONT OF BEDS 1 AND 2	PASS
10	CO DETECTOR	LOWER LEVEL REC ROOM	PASS
10	CO DETECTOR	BOTTOM OF STAIRS	PASS
11	SMOKE DETECTOR	1ST FLOOR MASTER BEDROOM	PASS
11	SMOKE DETECTOR	1ST FLOOR TOP OF STAIRS	PASS
11	SMOKE DETECTOR	1ST FLOOR OUTSIDE OF OFFICE	PASS
11	SMOKE DETECTOR	1ST FLOOR INSIDE OFFICE	PASS
11	SMOKE DETECTOR	1ST FLOOR GUEST BEDROOM	PASS
11	SMOKE DETECTOR	1ST FLOOR OUTSIDE OF GUEST BEDROOM	PASS
12	CO DETECTOR	1ST FLOOR MASTER BEDROOM	PASS





FIRE ALARM INSPECTION REPORT

INSP# 1036 5-2023

12	CO DETECTOR	1ST FLOOR TOP OF STAIRS	PASS
12	CO DETECTOR	1ST FLOOR OUTSIDE OF OFFICE	PASS
12	CO DETECTOR	1ST FLOOR INSIDE OFFICE	PASS
12	CO DETECTOR	1ST FLOOR GUEST BEDROOM	PASS
12	CO DETECTOR	1ST FLOOR OUTSIDE OF GUEST BEDROOM	PASS
13	SMOKE DETECTOR	2ND FLOOR BUNK ROOM 1	PASS
13	SMOKE DETECTOR	2ND FLOOR BUNK ROOM 2	PASS
13	SMOKE DETECTOR	2ND FLOOR OUTSIDE OF BUNK ROOMS	PASS
13	SMOKE DETECTOR	2ND FLOOR BEDROOM 4	PASS
13	SMOKE DETECTOR	2ND FLOOR OUTSIDE BEDROOM 4	PASS
14	CO DETECTOR	2ND FLOOR BUNK ROOM 1	PASS
14	CO DETECTOR	2ND FLOOR BUNK ROOM 2	PASS
14	CO DETECTOR	2ND FLOOR OUTSIDE OF BUNK ROOMS	PASS
14	CO DETECTOR	2ND FLOOR BEDROOM 4	PASS
14	CO DETECTOR	2ND FLOOR OUTSIDE BEDROOM 4	PASS

NOTIFICATION

ZONE	DEVICE TYPE	LOCATION	STATUS
	SMOKE DETECTOR	FACP SMOKE DETECTOR	PASS
	SMOKE DETECTOR	LOWER LEVEL IN FRONT OF ELEVATOR	PASS
	SMOKE DETECTOR	1ST FLOOR IN FRONT OF ELEVATOR	PASS
	SMOKE DETECTOR	2ND FLOOR IN FRONT OF ELEVATOR	PASS
	SMOKE DETECTOR	TOP OF ELEVATOR SHAFT	PASS
	SMOKE DETECTOR	LOWER LEVEL BED 2	PASS
	SMOKE DETECTOR	LOWER LEVEL BED 1	PASS
	SMOKE DETECTOR	LOWER LEVEL INFRONT OF BEDS 1 AND 2	PASS
	SMOKE DETECTOR	LOWER LEVEL REC ROOM	PASS
	SMOKE DETECTOR	BOTTOM OF STAIRS	PASS
	SMOKE DETECTOR	1ST FLOOR MASTER BEDROOM	PASS
	SMOKE DETECTOR	1ST FLOOR TOP OF STAIRS	PASS
	SMOKE DETECTOR	1ST FLOOR OUTSIDE OF OFFICE	PASS
	SMOKE DETECTOR	1ST FLOOR INSIDE OFFICE	PASS
	SMOKE DETECTOR	1ST FLOOR GUEST BEDROOM	PASS
	SMOKE DETECTOR	1ST FLOOR OUTSIDE OF GUEST BEDROOM	PASS
	SMOKE DETECTOR	2ND FLOOR BUNK ROOM 1	PASS
	SMOKE DETECTOR	2ND FLOOR BUNK ROOM 2	PASS





FIRE ALARM INSPECTION REPORT

INSP# 1036 5-2023

SMOKE DETECTOR	2ND FLOOR OUTSIDE OF BUNK ROOMS	PASS
----------------	---------------------------------	------

SMOKE DETECTOR	2ND FLOOR BEDROOM 4	PASS
----------------	---------------------	------

SMOKE DETECTOR	2ND FLOOR OUTSIDE BEDROOM 4	PASS
----------------	-----------------------------	------

XBATTERY

ZONE	DEVICE TYPE	LOCATION	STATUS
	12V7AH	PANEL	PASS
	12V7AH	POWER SUPPLY	PASS

THIS TESTING WAS PERFORMED IN ACCORDANCE WITH APPLICABLE STANDARDS

INSPECTOR NAME

INSPECTOR NUMBER

DATE SIGNED

Shawn Fitzgerald

C8097

5/9/23

CONTACT NAME

CONTACT TITLE

